



DECLARATION OF PERFORMANCE No I/2024 rev. I/2024

Producer: NGR TECHNOLOGIE Sp. z o. o.
Ul. Zielonogórska 8, 62-065 Grodzisk Wielkopolski

Product: Double telescopic leaf sliding door with pass door
CRFT MEC 120 MODELO VICTORIA

Harmonised norm(s): EN 16034:2014 & EN 13241:2003+A2:2016

Fire resistance: 120 minutes of fire integrity and thermal insulation

Fire Classification: EI₂ 120 according to EN13501-2

Certificate: 0370-CPR-3947

Certification body: N°0370, LGAI Technological Centre, S.A. (APPLUS+)

System of assessment and verification of constancy of performance: 1

Declared performances:

Essential characteristics	Clauses in the European standard	Mandated level(s) or class(es)
Fire resistance (for the compartmentation uses)	4.1	EI ₂ 120
Smoke control (only for applications where limitation of smoke spread is required)	4.2	Not applicable
Ability to release	4.3	Release
Self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)	4.4	C
Durability of ability to release	4.5.1	Release
Durability of self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)	4.5.2.1	0
-against degradation (cycling testing) -against ageing (corrosion)	4.5.2.2	Not applicable

The performance of the product identified above is consistent with the set of declared performance. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Date and place of issuing

Grodzisk Wielkopolski, 04.09.2024

Signature of the entitled person

"NGR TECHNOLOGIE" Sp. z o.o.
ul. Zielonogórska 8
62-065 Grodzisk Wlkp.
Tel. 61 44 45 165, fax 61 44 45 172
NIP 529-172-04-56, REGON 140567617
KRS 0000256477

PREZES ZARZADU
"NGR TECHNOLOGIE" Sp. z o.o.

Damian Wartecki