



## DECLARATION OF PERFORMANCE

**Producer:** NGR TECHNOLOGIE Sp. z o. o.  
Ul. Zielonogórska 8, 62-065 Grodzisk Wielkopolski

**Product:** Double telescopic leaf sliding door with pass door  
CRFTC MEC MODELO VICTORIA

**Harmonised norm(s):** EN 16034:2014 & EN 13241:2003+A2:2016

**Fire resistance:** 60 minutes of fire integrity and thermal insulation

**Fire Classification:** EI<sub>2</sub> 60 according to EN13501-2

**Certificate:** 0370-CPR-3945

**Certification body:** N°0370, LGAI Technological Centre, S.A. (APPLUS+)

**System of assessment and verification of constancy of performance:** 1

### Declared performances:

| Essential characteristics                                                                                               | Clauses in the European standard | Mandated level(s) or class(es) |
|-------------------------------------------------------------------------------------------------------------------------|----------------------------------|--------------------------------|
| Fire resistance (for the compartmentation uses)                                                                         | 4.1                              | EI <sub>2</sub> 60             |
| Smoke control (only for applications where limitation of smoke spread is required)                                      | 4.2                              | Not applicable                 |
| Ability to release                                                                                                      | 4.3                              | Release                        |
| Self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)               | 4.4                              | C                              |
| Durability of ability to release                                                                                        | 4.5.1                            | Release                        |
| Durability of self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows) | 4.5.2.1                          | 0                              |
| -against degradation (cycling testing)<br>-against ageing (corrosion)                                                   | 4.5.2.2                          | Not applicable                 |

Declared performances will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Date and place of issuing

Grodzisk Wielkopolski, 24.04.2020

Signature of the entitled person

"NGR TECHNOLOGIE" Sp. z o.o.  
ul. Zielonogórska 8  
62-065 Grodzisk Wielkopolski  
Tel. 01 44 7 1 173, fax 01 44 7 1 172  
KRP 00017404-1, REGON 1406017  
NIP 0000250477

PREZES ZARZĄDU  
"NGR TECHNOLOGIE" Sp. z o.o.  
*Damian Wartecki*