



DECLARATION OF PERFORMANCE 02/2020

Producer: NGR TECHNOLOGIE Sp. z o. o.
Ul. Zielonogórska 8, 62-065 Grodzisk Wielkopolski

Product: Fireproof vertical sliding gate (GUILLLOTINE) GRFT-MEC

Harmonised norm(s): EN 16034:2014, EN 13241:2003+A2:2016

Fire resistance: 120 minutes of fire integrity and thermal insulation

Fire classification: EI₂ 120 according to EN13501-2

Certificate: 0370-CPR-3951

Certification body: N°0370, LGAI Technological Centre, S.A. (APPLUS+)

System of assessment and verification of constancy of performance: 1

Declared performances:

Essential characteristics	Clauses in the European standard	Mandated level(s) or class(es)
Fire resistance (for the compartmentation uses)	4.1	EI ₂ 120
Smoke control (only for applications where limitation of smoke spread is required)	4.2	Not applicable
Ability to release	4.3	Release
Self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)	4.4	C
Durability of ability to release	4.5.1	Not applicable
Durability of self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)	4.5.2.1	0
-against degradation (cycling testing) -against ageing (corrosion)	4.5.2.2	Not applicable

Declared performances will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Date and place of issuing

Grodzisk Wielkopolski, 24.04.2020

Signature of the entitled person

"NGR TECHNOLOGIE" Sp. z o.o.
ul. Zielonogórska 8
62-065 Grodzisk Wielkop.
Tel. 61 74 41 175, fax 61 74 45 172
NIP 525-174-04-44, Regon 140627617
KRS 0000253477

PREZES ZARZĄDU
"NGR TECHNOLOGIE" Sp. z o.o.
Damian Wartecki