



DECLARATION OF PERFORMANCE

Producer: NGR TECHNOLOGIE Sp. z o. o.
Ul. Zielonogórska 8, 62-065 Grodzisk Wielkopolski

Product: Single leaf sliding door
CRF MEC 180 MODELO VICTORIA

Harmonised norm(s): EN 16034:2014 & EN 13241:2003+A2:2016

Fire resistance: 180 minutes of fire integrity and thermal insulation

Fire Classification: EI₂ 180 according to EN13501-2

Certificate: 0370-CPR-3950

Certification body: N°0370, LGAI Technological Centre, S.A. (APPLUS+)

System of assessment and verification of constancy of performance: 1

Declared performances:

Essential characteristics	Clauses in the European standard	Mandated level(s) or class(es)
Fire resistance (for the compartmentation uses)	4.1	EI ₂ 180
Smoke control (only for applications where limitation of smoke spread is required)	4.2	Not applicable
Ability to release	4.3	Release
Self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)	4.4	C
Durability of ability to release	4.5.1	Release
Durability of self-closing (only for self-closing fire resistant and/or smoke control doorsets and/or openable windows)	4.5.2.1	0
-against degradation (cycling testing) -against ageing (corrosion)	4.5.2.2	Not applicable

Declared performances will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Date and place of issuing

Grodzisk Wielkopolski, 24.04.2020

Signature of the entitled person

"NGR TECHNOLOGIE" Sp. z o.o.
ul. Zielonogórska 8
62-065 Grodzisk Wielkopolski
Tel. 61 44 77 145, fax 61 44 77 172
NIP 529-172-04-44, REGON 1424617
KRS 000025677

PREZES ZARZĄD
"NGR TECHNOLOGIE" Sp. z o.o.
Damian Wartecki